



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Insulation Materials

(Details as per the attached Scope of Certification)

manufactured by:

EMIRATES EXTRUDED POLYSTYRENE

Plot No. 598-119, Dubai Investment Park, Dubai, UAE

Have been processed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2018 UAE Fire and Life Safety Code of Practice

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



ARIF AL MARZOOQI

« Certification and Quality Control of Products Section Manager
Dubai Central Laboratory Department-Dubai Municipality

Current Issue Date: 18/08/2023
Original Issue Date: 18/08/2023



Current Issue Date: 18/08/2023
Original Issue Date: 18/08/2023



This attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate and its electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

OPEN DATA

DM-DCLD-F-ID-2031 Rev 02



بلدية دبي
A pioneering Municipality for a global city

800 900
dm.gov.ae



DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL23020842

Certificate Issued To:	EMIRATES EXTRUDED POLYSTYRENE LLC Plot 598-119, Dubai Investment Park, Dubai, UAE
Applicable Standard Specification:	2018 UAE Fire & Life Safety Code of Practice
Applicable Specific Rules:	DM-DCLD-RD-DP21-2210 (IC) - Certification of Thermal Materials for Compliance to the requirements of UAE Fire and Life Safety Code of Practice 2018

S/N	Product Description	Brand Name	Product Details
1.	Rigid Cellular Extruded Polystyrene Thermal Insulation Board	E-FOAM	Extruded (XPS) Polystyrene Thermal Insulation Board Type VII (Density – 35 kg/m ³ minimum) Size: 1250 x 600 mm Thickness: 25-100 mm Fire Properties: Class A (tested as per ASTM E84) (Flame Spread: 25 max, Smoke development: 450 max) complies with 2018 UAE Fire and Life Safety Code for Test 1 of Table 1.15a: EIFS & ETICS on Non-Fire Resistance rated and Non-Load bearing Exterior wall coverings



DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL23020842

			<p>For the following occupancy & type of building such as: any building, any installation, any aesthetics</p> <p>Fire Properties: Class A (tested as per ASTM E84) (Flame Spread: 25 max, Smoke development: 450 max) complies with</p> <p>2018 UAE Fire and Life Safety Code for Test 1 of Tables 1.15b: EIFS & ETICS on Fire Resistance rated Exterior wall coverings.</p> <p>For the following occupancy & type of building such as: any building, any installation, any aesthetics</p>
--	--	--	--

Note 1: This document forms an integral part of the Certificate of Product Conformity bearing the same certificate number.

Note 2: The Fire safety test results meet the requirements of the 2018 UAE Fire and Life Safety Code of Practice as an insulation material.

Original Issue Date: 18 August 2023

Current Issue Date: 18 August 2023

Valid Until: 17 August 2024

ARIF HUSAIN AL MARZOOQI

MANAGER

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION